

**SIGNIFICANT PERMIT REVISION NO. 45568
TO PERMIT NO. 29147
Transwestern Pipeline Company, LLC - Flagstaff Compressor Station**

SIGNIFICANT PERMIT REVISION DESCRIPTION

This Significant Permit Revision to Operating Permit No.29147, issued to Transwestern Pipeline Company, LLC for operation of a pipeline compressor station at Flagstaff, authorizes changes in fuel gas sulfur monitoring requirements for the gas turbine resulting from changes promulgated under 40 CFR 60 Subpart GG. The revision also incorporates changes in the permit due to deletion of an emergency generator (rated at 519 hp) and heater (rated at 1.0 MMBtu/hr)

This Significant Revision No. 45568 will result in the following changes to the Permit No. 29147:

ATTACHMENT “B”

1. Conditions II.D.2 and II.D.3 shall be amended to read follows:

II. GAS TURBINE ENGINE

D. Sulfur Dioxide

2. Monitoring and Recordkeeping Requirements

The Permittee shall demonstrate that the gaseous fuel burned in the gas turbine meets the definition of “natural gas” in 40 CFR 60.331(u) by maintaining a current, valid purchase contract, tariff sheet, or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20 grains/100 scf or less.

[40 CFR 60.334(h)(3)(i)]

3. Permit Shield

Compliance with the conditions of this Section shall be deemed compliance with 40 CFR 60.333(b) and 40 CFR 60.334(h)(3)(i).

[A.A.C. R18-2-325]

2. Conditions III.B.2, III.C.2, III.C.3.a, III.C.3.b, III.D.2.c and III.E.2.a pertaining to the emergency diesel generator are deleted.
3. Section IV pertaining to the heater is deleted.

This page was left blank intentionally.

ATTACHMENT “C” – Equipment list shall read as below:

ATTACHMENT “C”: EQUIPMENT LIST
Air Quality Control Permit No. 29147
(As revised by Significant Permit Revision No. 45568)
for

Transwestern Pipeline Company, Flagstaff Compressor Station

| EQUIPMENT TYPE | MAX. CAPACITY | MAKE | MODEL | Emission Unit ID | DATE OF MFG. | NSPS APPLICABLE |
|---------------------------|--------------------------|---------------------|--------------|-----------------------------|-----------------------------|----------------------------|
| Compressor Turbine | 30,565 HP | General Electric | LM 2500 | 204 | 2001 | YES |
| Generator | 526 HP | Caterpillar | G3508 | 223 | 2001 | NO |
| Generator | 526 HP | Caterpillar | G3508 | 224 | 2001 | NO |